



VERIFIED COMPATIBILITY

Gateway Web Server

Ch 27 Temperature sensor with correction



Object ID	Value Name	Range	Value
AI 2700	Set point	0...255	184
AI 2701	Temperature	0...40 °C	22.745°C
AI 2702	Occupancy	1:Button released;0:...	1:Button released
AI 2790	Telegram counter	0...65535	4
AI 2791	Telegram age	0...65000 s	136s
MSV 2799	CONFIG	1:FREE;2:ASSIGNED	2:ASSIGNED

Temperature sensor with Ch 27

184
22.7°C
1



Temperature sensor with correction



Gateway Web Server

Ch 28 Multisensor

Object ID	Value Name	Range	Value
AI 2800	Temperature	-40...60 °C	24°C
AI 2801	Humidity	0...100 %	50.5%
AI 2802	Illumination	0...100000 lx	241lx
AI 2803	Acceleration Status	0:Heartbeat;1:Thresh...	0:Heartbeat
AI 2804	Acceleration X	-2500...2500 mG	-65mG
AI 2805	Acceleration Y	-2500...2500 mG	25mG
AI 2806	Acceleration Z	-2500...2500 mG	1020mG
AI 2807	Contact	0:Open;1:Closed	0:Open
AI 2890	Telegram counter	0...65535	32
AI 2891	Telegram age	0...65000 s	8s
MSV 2899	CONFIG	1:FREE;2:ASSIGNED	2:ASSIGNED

Multisensor Ch 28

24.2°C
50.5%
192lx



Multisensor

www.firvena.cz

www.regmet.cz

